Renewable to Retail Locational Loss Factors for 2025

The Locational Loss Factors applicable to the Renewable to Retail Energy Balancing Services Tariff for 2025 are shown in the table below. The values in this table are reviewed and updated annually. Zonal losses, maps and descriptions are maintained by the Nova Scotia Power System Operator (NSPSO).

Zone	Zone Description	Locational Loss Factor Table					
		Average Annual Generation Capacity (N.P. x C.F.) 1,2					
		30 MW	25 MW	20 MW	15 MW	10 MW	5 MW
1	EAST	6.5%	6.3%	6.2%	5.9%	5.2%	4.1%
2	NORTHEAST	3.3%	3.0%	2.9%	2.9%	2.1%	1.2%
3	METRO	0.5%	0.1%	0.1%	0.2%	-0.6%	-0.9%
4	EAST VALLEY / SOUTH SHORE	0.0%	-0.4%	-0.5%	-0.7%	-1.9%	-2.5%
5	WEST VALLEY	-	-	-	2.2%	0.4%	-0.8%

